

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
S 50317989

Blatt *Page*  
0001

Ihr Zeichen *Client Reference*      Unser Zeichen *Our Reference*      Längstens gültig bis *Latest expiration date*  
U.      02-YANGLAU- 17026184 004 19.08.2020      (day/mo/yr)

**Genehmigungsinhaber *License Holder***  
FLUKE DEUTSCHLAND GMBH  
In den Engematten 14  
79286 Glottertal  
Germany

**Fertigungsstätte *Manufacturing Plant***  
HDT (Dongguan) Ltd.  
HDT Industrial Zone, No. 29th  
Fuxing Rd., Xiagang Zone  
Chang'an Town  
Dongguan, Guangdong 523872  
P.R. China

## Prüfzeichen *Test Mark*



**Geprüft nach *Tested acc. to***  
EN 61243-3:2010  
EN 61010-1:2010  
EN 61010-2-033:2012  
EN 60529:1991+A1  
AfPS GS 2014:01

**Zertifiziertes Produkt *(Geräteidentifikation)***  
***Certified Product (Product Identification)***

**Lizenzentgelte - Einheit**  
***License Fee - Unit***

## Spannungsprüfer *(Two Pole Voltage Tester)*

Bezeichnung : 2100-Beta 2100-Gamma  
(Type Designation) (BEHA-AMPROBE) (AMPROBE) 6  
Detektionsspannung : 12 - 690V (For 2100-Beta)  
(Detecting Voltage) 6 - 1000 V (for 2100-Gamma)  
Überspannungskategorie : CAT III 690V, CAT IV 600V  
(Overvoltage Category) (For 2100-Beta)  
CAT III 1000V, CAT IV 600V  
(for 2100-Gamma)  
Betriebsfrequenz : DC; AC 16 2/3-400Hz  
(Operating Frequency)  
Betrieb : 30s AN/240s AUS  
(Operation) (30s ON/240s OFF)  
Schutzklasse : II  
(Protection Class)  
Schutzart : IP64  
(Degree of Protection)  
Umgebungstemperatur : -15°C to 55°C  
(Ambient Temperature)

6

## ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Produkt und Fertigungsstätte erfüllen § 20 und § 21 des  
Produktsicherheitsgesetzes.

*This certificate is based on our Testing and Certification Regulation.  
Product and production fulfill par § 20 and § 21 of the  
Product Safety Law.*

**TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg**  
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com  
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

**Ausstellungsdatum *Date of Issue* : 20.08.2015 (day/mo/yr)**

Zertifizierungsstelle



Dipl.-Ing. (FH) C. Padel

FLUKE DEUTSCHLAND GMBH  
Mr. Unmuessig  
-  
In den Engematten 14  
79286 Glottertal  
Germany

Date : 20.08.2015  
Our ref. : YANGLAU 02  
Your ref.: U.

**Ref : S GS-Mark Approval**

Type of Equipment : Two Pole Voltage Tester  
Model Designation : See Certificate  
Certificate No. : S 50317989 0001  
Report No. : 17026184 004

Dear Mr. Unmuessig,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.


Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body

  
Dipl.-Ing. (FH) C. Padel

Enclosure

证书的详细资料请登陆[www.tuvdotcom.com](http://www.tuvdotcom.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询